

# SWEDISH TECHNICAL APPROVAL

**0117/06**

*The product described below and production control has been found to comply with Building Regulations of the National Board of Housing Building and Planning (BBR) with reference to and under conditions described in this approval.*

## Floor gully, Purus MiniMax 50

Holder	Purus AB, Södra Dragongatan 15, 271 39 Ystad. Tel: 010-414 49 00, fax: 010-414 49 96, e-mail: <a href="mailto:info@purus.se">info@purus.se</a> Internet: <a href="http://www.purus.se">www.purus.se</a> VAT number: 556361-1887.				
Product	Floor gully Purus MiniMax 50 consists of gully body, water trap, clamping ring and grating with Ø 130 mm. All parts are made of PP. MiniMax 50 has side outlet in dimension Ø 50 mm.				
Intended use	Purus Våke is intended for domestic waste water and for installation in concrete or timber floor constructions with plastic or clinker surface.				
Trade name	Purus MiniMax 50, RSK no. 7113764.				
Approval	The product has been found to meets the requirements in the following sections of the Building and/or Construction Regulations of the National Board of Housing, Building and Planning (BBR): <table><tr><td>Waste water installations</td><td>6:641, 1:st and 2:nd paragraph</td></tr><tr><td>Design</td><td>6:644, 1:st sentence and 2:nd paragraph</td></tr></table> <p>Waste water installations shall be designed in such a way that they can continuously drain at least 150% of the draw-off flow-rates of the water outlets.</p>	Waste water installations	6:641, 1:st and 2:nd paragraph	Design	6:644, 1:st sentence and 2:nd paragraph
Waste water installations	6:641, 1:st and 2:nd paragraph				
Design	6:644, 1:st sentence and 2:nd paragraph				
Associated documents	Installation instruction Purus floor gullies 130 MiniMax, dated 2011-101-21. Maintenance of Purus floor gullies, version 2011:1.				
Control	Production control is to be performed in accordance with instructions for control dated 2011-06-14. An independent inspection body audits the control. Control agreement: 210-97-0648. Inspection body: SP Technical Research Institute of Sweden.				


Control (cont.)	When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents.																												
Manufacturer	Production control includes the following sites: Purus AB, Södra Dragongatan 15, 271 39 Ystad. Purus AB, Hasselgatan 25, 333 32 Smålandsstenar.																												
Marking	The products are to be marked at the factory. The marking consists of a text on every product and packaging supplied and includes:  <table border="0" style="margin-left: 20px;"> <tr> <td><u>Packing are marked with:</u></td> <td></td> </tr> <tr> <td>Approval holder</td> <td style="text-align: right;"><b>Purus</b></td> </tr> <tr> <td>Boverket's registered trademark</td> <td style="text-align: right;"><b>†</b></td> </tr> <tr> <td>Certification body and accreditation number</td> <td style="text-align: right;"><b>SP SITAC 1002</b></td> </tr> <tr> <td>Approval number</td> <td style="text-align: right;"><b>0117/06</b></td> </tr> <tr> <td>Product type designation</td> <td style="text-align: right;"><b>MiniMax 50</b></td> </tr> <tr> <td>RSK number</td> <td style="text-align: right;"><b>711 37 64</b></td> </tr> <tr> <td>Inspection body</td> <td style="text-align: right;"><b>SP</b></td> </tr> <tr> <td colspan="2"> <u>Products are marked with:</u></td> </tr> <tr> <td>Approval holder</td> <td style="text-align: right;"><b>Purus</b></td> </tr> <tr> <td>Consecutive production month/year</td> <td style="text-align: right;"><b>month/year</b></td> </tr> <tr> <td>RSK number clamping ring, KL 130</td> <td style="text-align: right;"><b>714 13 16</b></td> </tr> <tr> <td>RSK number Nood MiniMax water trap</td> <td style="text-align: right;"><b>711 37 65</b></td> </tr> <tr> <td>RSK number grating, 130 Plastic</td> <td style="text-align: right;"><b>713 84 47</b></td> </tr> </table>	<u>Packing are marked with:</u>		Approval holder	<b>Purus</b>	Boverket's registered trademark	<b>†</b>	Certification body and accreditation number	<b>SP SITAC 1002</b>	Approval number	<b>0117/06</b>	Product type designation	<b>MiniMax 50</b>	RSK number	<b>711 37 64</b>	Inspection body	<b>SP</b>	 <u>Products are marked with:</u>		Approval holder	<b>Purus</b>	Consecutive production month/year	<b>month/year</b>	RSK number clamping ring, KL 130	<b>714 13 16</b>	RSK number Nood MiniMax water trap	<b>711 37 65</b>	RSK number grating, 130 Plastic	<b>713 84 47</b>
<u>Packing are marked with:</u>																													
Approval holder	<b>Purus</b>																												
Boverket's registered trademark	<b>†</b>																												
Certification body and accreditation number	<b>SP SITAC 1002</b>																												
Approval number	<b>0117/06</b>																												
Product type designation	<b>MiniMax 50</b>																												
RSK number	<b>711 37 64</b>																												
Inspection body	<b>SP</b>																												
 <u>Products are marked with:</u>																													
Approval holder	<b>Purus</b>																												
Consecutive production month/year	<b>month/year</b>																												
RSK number clamping ring, KL 130	<b>714 13 16</b>																												
RSK number Nood MiniMax water trap	<b>711 37 65</b>																												
RSK number grating, 130 Plastic	<b>713 84 47</b>																												
Basis for approval	Report ETkP503932 and ETkP503932-1 from SP Technical Research Institute of Sweden. Report 270-9-0831A from DTI, Danmark.																												
Comments	Installation instructions shall be delivered in each package. Purus Våke is approved according to standard SS-EN 1253-1:2003. The function of the partially mechanical trap has been deemed to correspond to a trap depth of 50 mm. The removable water trap needs to be cleaned regularly.																												

This approval supersedes the previous certificate with the same number dated 2006-12-05 with project number T600117.



Period of validity

This approval is valid until 2017-04-02.

  
Ronald Green

  
Marcus Tillman

